



## ***2006 Annual Drinking Water Report***

We're pleased to present to you this year's Annual Water Quality Report or Consumers Confidence Report as prescribed by the State of Wisconsin Statutes. This report is designed to comply with the 1996 amendment to the Safe Drinking Water Act. It is to inform you about the water quality and services we deliver to you everyday. Our constant goal is to provide you with a safe and dependable supply of drinking water. Our water is purchased from the City of Racine Water Utility.

The Racine Water Utility treats water from Lake Michigan and sells it to several communities within Racine and Kenosha Counties. We, along with the Racine Water Utility, want you to understand the efforts, which are continually made to improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. We want our valued customers to be informed about their water utility.

### ***This report shows our water quality and what it means.***

If you have any questions about this report or concerning your water utility, please contact the Village office at 886-7204. If you would like to learn more, please attend any of our regularly scheduled meetings. The Village Board meetings are the first and third Tuesday of each month at 6:00 pm in the Village Hall. You can review this report on the Village of Sturtevant web page: [www.sturtevant-wi.gov](http://www.sturtevant-wi.gov)

The Village of Sturtevant and our water provider, Racine Water Utility, routinely monitor for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of calendar year 2005. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk.

### ***Terms and abbreviations***

*Non-Detects (ND)* - laboratory analysis indicates that the constituent is not present.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

*Nephelometric Turbidity Unit (NTU)* - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

*Action Level* - the concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.

*Pico Curies per Liter (pCi/L)* – A measurement of radioactivity.

*Treatment Technique (TT)* - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

*Nephelometric Turbidity Units (NTU)* – A measurement of turbidity.

*Maximum Contaminant Level* - The “Maximum Allowed” (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal* - The “Goal”(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

As you can see by the table on the next page, our system had no violations. We’re proud that your drinking water exceeds all Federal and State requirements. Our testing show that some constituents have been detected, but the EPA has determined that your water **IS SAFE** at these levels. The official Consumer Confidence Report for the City of Racine is available for inspection at the Village Hall.

“All sources of drinking water are subject to potential contamination by contaminants that are naturally occurring or is man made. Those contaminants can be microbes, organic or inorganic chemicals, or radioactive materials.”

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency’s Safe Drinking Water Hotline at 1-800-426-4791.

MCL’s are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

In our continuing efforts to maintain a safe and dependable water supply it may be necessary to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. Your understanding is appreciated.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

# Sturtevant Water Utility

# Water Quality data from 2005 for 2006 Water Quality Report

## Microbiological Results

Contaminant	MCLG	MCL	Highest Monthly	Violation	Major Source
Total Coliform Bacteria	0	<5%/month	0.00%	No	Human and animal fecal waste
Viruses, Giardia	0	TT			Human and animal fecal waste
Legionella	0	TT			Found naturally in water, multiplies in heating systems

## Regulated Inorganic Results

Contaminant	MCLG	MCL	Results	Violation	Major Source
Antimony (ppb)	6	6	<0.1	No	Discharge from petroleum refineries, fire retardants, ceramics, electronics, solder
Arsenic (ppb)	10	10	<2.0	No	Erosion of natural deposits
Asbestos (million fibers per liter)		7	<0.174	No	Erosion of natural deposits
Barium (ppm)	2	2	0.017	No	Erosion of natural deposits
Beryllium (ppb)		4	<0.03	No	
Cadmium (ppb)		5	<1.0	No	
Chromium (ppb)		100	2.6	No	Erosion of natural deposits
Cyanide (ppm)		0.2	<0.02	No	
Fluoride (ppm)		4	Average: 1.04 Range: 0.11" - 1.31	No	Water additive which promotes strong teeth, erosion of natural deposits, discharge from fertilizer and aluminum factories
Mercury (ppb)		2	<0.1	No	Erosion of natural deposits
Nickel (ppb)		100	3.5	No	Erosion of natural deposits
Nitrate (ppm)	10	10	0.24	No	Runoff from fertilizer use, leaching from septic tanks, sewage Erosion of natural deposits
Nitrite (ppm)	1	1	<0.01	No	Runoff from fertilizer use, leaching from septic tanks, sewage Erosion of natural deposits
Selenium (ppb)		50	<2.0	No	Erosion of natural deposits
Thallium (ppb)		2	<0.4	No	Erosion of natural deposits

## Organic Results

Contaminant	MCLG	MCL	Results	Violation	Major Source
THM (ppb) (total trihalomethanes)	0	80	18.1 Range: 12.1 - 26.6	No	By-product of drinking water chlorination
HAA (ppb) (haloacetic acids)	0	60	10.8 Range: 8.4 - 14.6	No	By-product of drinking water chlorination
Synthetic Organic Compounds	40 compounds tested, non detected			No	Runoff from fertilizer use, leaching from septic tanks, sewage
Volatile Organic Compounds	41 compounds tested, non detected			No	Discharge from industry, cleaners

## Lead and Copper Results Tests Performed in 2004

### Results of Lead and Copper Sampling at Residential Water Taps

Contaminant	Number of sites Exceeding A.L.	MCLG	Action Level	90% Level Violation	Major Source
Copper (ppm)	0	1.3	A.L. = 1.3	No	Corrosion of household plumbing systems, Erosion of natural deposits
Lead (ppb)	0	0	A.L. = 15	No	Corrosion of household plumbing systems, Erosion of natural deposits

## Particulate Results

Contaminant	MCLG	MCL	Results	Violation	Major Source
Turbidity (NTU)	na	TT Never > 5 95% of time < 0.5	Highest = 0.12 Average Daily Highest = 0.07	No	Soil runoff, suspended matter in source water

## Radiological Results Combined Radium Tested in 2000, Gross Alpha and Beta Tested in 2002

Contaminant	MCLG	MCL	Results	Violation	Major Source
Beta photo Emitters (pCi/l)	0	50	1.6	No	Decay of natural and man-made deposits
Alpha Emitters (pCi/l)	0	15	0.4	No	Erosion of natural deposits
Combined Radium (pCi/l)	0	5	0.8	No	Erosion of natural deposits

## Unregulated Contaminant Results

Contaminant	MCLG	MCL	Results	Violation	Major Source
Sodium (ppm)	na	na	6.6		Erosion of natural deposits
Sulfate (ppm)	na	na	26		Erosion of natural deposits
Ortho-phosphate (ppm)	na	na	0.24		Erosion of natural deposits, addition of chemical in water treatment
Iron (ppm)	na	na	0.02		Erosion of natural deposits, addition of chemical in water treatment
Total Organic Carbon (ppm)			1.58		Decay of natural and man-made deposits

\* Low fluoride levels due to Hurricane Katrina interrupting manufacturing of chemical.